



CERTIFICATE OF AUTHENTICITY

THIS IS TO CERTIFY THAT THE FOLLOWING ELECTRONIC RECORDS ARE TRUE AND ACCURATE REPRODUCTIONS OF THE ORIGINAL RECORDS OF JAMES CITY COUNTY GENERAL SERVICES DEPARTMENT- STORMW ATER DIVISION; WERE SCANNED IN THE REGULAR COURSE OF BUSINESS PURSUANT TO GUIDELINES ESTABLISHED BY THE LIBRARY OF VIRGINIA AND ARCHIVES; AND HAVE BEEN VERIFIED IN THE CUSTODY OF THE INDIVIDUAL LISTED BELOW.

BMP NUMBER: 66003

DATE VERIFIED: February 10, 2022

QUALITY ASSURANCE TECHNICIAN: Charles E. Lovett II

Charles E. Lovett II

LOCATION: WILLIAMSBURG, VIRGINIA

NOTES: CERTIFY & UPLOAD



July 11, 2008

TO: **H. H. Hunt Communities, Inc.**
11237 Nuckols Road
Glen Allen, Virginia 23059
Attn: Mr. Dan Mason, P.E.

RE: Alley Pavement Design Alternative
White Hall Section I
James City County, Virginia
G E T Solutions, Inc. Project No. WM07-225T

Dear Mr. Mason:

We understand that in order to satisfy ADA requirements, it will be necessary to alter the current alley pavement section of 6 inches Aggregate Base Material and 2 inches Asphalt Surface Material to allow for a two course asphalt section, the first course being the temporary wearing surface prior to a final overlay. The following alternative alley pavement section could be considered to satisfy this purpose:

Aggregate Base: Minimum 4.5 inches of Aggregate Base Material meeting 21-A gradation.

Asphalt Base: Minimum 2.0 inches of Intermediate Asphalt Concrete, IM-19.0 or equivalent.

Asphalt Surface: Minimum 1.5 inches of Surface Asphalt Concrete, SM-9.5A or equivalent.

We trust that the information contained herein meets your immediate needs, and we would ask that you call this office with any questions that you may have.

Respectfully Submitted,
G E T Solutions, Inc.

Sara B. Phillips
Project Geologist



Robert C. Moss, III, P.E.
Senior Geotechnical Engineer
VA Reg. # 019982

Copies: (1) Client via email
(1) AES Consulting Engineers via email - Aaron Small, PE